



For the following equipment :

Product Description: 150W, Single Phase DIN rail Switching Power Supply

Model Designation: MEPS150-24

Complies with the requirements set out in the European Council Directive.
The following standards were applied:

RoHS Directive	2011/65/EU
Low Voltage Directive	2014/35/EU
Safety Standards	EN60950-1:2006+A11:2009+A1:2010+A12:2011+A2:2013
	EN50178:1998

Electromagnetic Compatibility Directive 2014/30/EU

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN55011:2009+A1:2010	Class	B
EN55022:2010	Class	B
EN61204-3:2011		

<i>Harmonic current</i>	EN61000-3-2:2014	Class	A
-------------------------	------------------	-------	---

EMS (Electro-Magnetics Susceptibility)

<i>Generic immunity standard for industrial environments</i>	EN61000-6-2:2005
--	------------------

<i>ESD air</i>	EN61000-4-2:2008	Level	3
----------------	------------------	-------	---

<i>ESD contact</i>	EN61000-4-2:2008	Level	2
--------------------	------------------	-------	---

<i>RF field susceptibility</i>	EN61000-4-3:2006+A1:2007+A2:2010	Level	3
--------------------------------	----------------------------------	-------	---

<i>EFT bursts</i>	EN61000-4-4:2012	Level	4
-------------------	------------------	-------	---

<i>Surge susceptibility</i>	EN61000-4-5:2014	Level	4
-----------------------------	------------------	-------	---

<i>Voltage dip interruption</i>	EN61000-4-11:2004+A1:2010	Class	2
---------------------------------	---------------------------	-------	---

Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturer must re-qualify EMC Directive on the complete system again.

Person responsible for this declaration :

Nextys SA
(Manufacturer Name)

Via Luserte Sud 6, 6572 Quartino - Switzerland
(Manufactures Address)

Marius Ciorica / Product Manager
(Name / Position)


(Signature)

Quartino
(Place)

11.04.2017
(Date)